



Certificate of Compliance

Certificate: 80037982

Master Contract: 261002

Project: 80037982

Date Issued: 2020-06-12

Issued to: Hoymiles Converter Technology Co., Ltd.
No.18 Kangjing Road,
Hangzhou, Zhejiang 310015
CHINA
Attention: Xingyao Zhang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yang (Jason) Lei
Yang (Jason) Lei

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Grid Support Utility Interactive Inverter, Models HM-250, HM-250N, HM-250T, HM-250NT, HM-250A, HM-250NA, HM-300, HM-300N, HM-300T, HM-300NT, HM-300A, HM-300NA, HM-350, HM-350N, HM-350T, HM-350NT, HM-350A, HM-350NA, HM-400, HM-400N, HM-400T, HM-400NT, HM-400A, HM-400NA, HM-450, HM-450N, HM-450T, HM-450NT, HM-450A and HM-450NA, Rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

*Note: This product is PV Rapid Shut Down Equipment and conforms with NEC-2014 and NEC-2017 Article 690.12 and CEC-2018 Sec 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according to manufacturer's instructions.



Certificate: 80037982

Master Contract: 261002

Project: 80037982

Date Issued: 2020-06-12

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 107.1-16 - Power Conversion Equipment

*UL Std. No. 1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision dated February 15, 2018)

*Note: Conformity to UL 1741-Second Edition (February 15, 2018) includes compliance with applicable requirements of IEEE 1547-2003(R2008) , IEEE 1547.1-2005 (R2011) and California Rule 21 and Supplement SA.